

## APPENDIX E: SAR SYSTEM VALIDATION

Per FCC KDB Publication 865664 D02v01r02, SAR system validation status should be documented to confirm measurement accuracy. The SAR systems (including SAR probes, system components and software versions) used for this device were validated against its performance specifications prior to the SAR measurements. Reference dipoles were used with the required tissue- equivalent media for system validation, according to the procedures outlined in FCC KDB Publication 865664 D01v01r04 and IEEE 1528-2013. Since SAR probe calibrations are frequency dependent, each probe calibration point was validated at a frequency within the valid frequency range of the probe calibration point, using the system that normally operates with the probe for routine SAR measurements and according to the required tissue-equivalent media.

A tabulated summary of the system validation status including the validation date(s), measurement frequencies, SAR probes and tissue dielectric parameters has been included.

**Table E-1**  
**SAR System Validation Summary – 1g and 10g**

SAR System	Freq. (MHz)	Date	Probe SN	DAE	Probe Cal Point		Cond. ( $\sigma$ )	Perm. ( $\epsilon_r$ )	CW VALIDATION			MOD. VALIDATION		
					SENSITIVITY	PROBE LINEARITY			MOD. TYPE	DUTY FACTOR	PAR			
AM11	2450	05/06/2025	7551	1323	2450	Head	1.838	39.533	PASS	PASS	PASS	OFDM/TDD	PASS	PASS
AM11	5250	05/08/2025	7551	1323	5250	Head	4.633	35.645	PASS	PASS	PASS	OFDM	N/A	PASS
AM11	5600	05/08/2025	7551	1323	5600	Head	4.993	35.063	PASS	PASS	PASS	OFDM	N/A	PASS
AM11	5750	05/08/2025	7551	1323	5750	Head	5.160	34.812	PASS	PASS	PASS	OFDM	N/A	PASS
AM11	5850	05/08/2025	7551	1323	5850	Head	5.366	35.910	PASS	PASS	PASS	OFDM	N/A	PASS

NOTE: While the probes have been calibrated for both CW and modulated signals, all measurements were performed using communication systems calibrated for CW signals only. Modulations in the table above represent test configurations for which the measurement system has been validated per FCC KDB Publication 865664 D01v01r04 for scenarios when CW probe calibrations are used with other signal types. SAR systems were validated for modulated signals with a periodic duty cycle, such as GMSK, or with a high peak to average ratio (>5 dB), such as OFDM according to FCC KDB Publication 865664 D01v01r04.

FCC ID: BCG-A3122	RF EXPOSURE REPORT	Approved by: Technical Manager
DUT Type: Wireless Earbuds Charging Case	APPENDIX E: Page 1 of 1	