

APPENDIX G: SAR SYSTEM VALIDATION

Per FCC KDB Publication 865664 D02v01r02, SAR system validation status should be documented to confirm measurement accuracy. The SAR systems (including SAR probes, system components and software versions) used for this device were validated against its performance specifications prior to the SAR measurements. Reference dipoles were used with the required tissue- equivalent media for system validation, according to the procedures outlined in FCC KDB Publication 865664 D01v01r04 and IEEE 1528-2013. Since SAR probe calibrations are frequency dependent, each probe calibration point was validated at a frequency within the valid frequency range of the probe calibration point, using the system that normally operates with the probe for routine SAR measurements and according to the required tissue-equivalent media.

A tabulated summary of the system validation status including the validation date(s), measurement frequencies, SAR probes and tissue dielectric parameters has been included.

Table G-1
SAR System Validation Summary

SAR System	Freq. (MHz)	Date	Probe SN	DAE	Probe Cal Point	Cond. (σ)	Perm. (ϵ_r)	CW VALIDATION			MOD. VALIDATION		
								SENSITIVITY	PROBE LINEARITY	PROBE ISOTROPY	MOD. TYPE	DUTY FACTOR	PAR
O	2450	06/05/2024	3914	728	2450	Head	1.827	37.860	PASS	PASS	OFDM/TDD	PASS	PASS
J	2450	08/29/2024	7406	1677	2450	Head	1.833	39.715	PASS	PASS	OFDM/TDD	PASS	PASS
S	5250	07/19/2024	7803	1583	5250	Head	4.685	35.198	PASS	PASS	OFDM	N/A	PASS
S	5600	07/19/2024	7803	1583	5600	Head	5.085	34.550	PASS	PASS	OFDM	N/A	PASS
S	5750	07/19/2024	7803	1583	5750	Head	5.262	34.250	PASS	PASS	OFDM	N/A	PASS
S	5850	07/19/2024	7803	1583	5850	Head	5.380	34.060	PASS	PASS	OFDM	N/A	PASS
R	6500	07/18/2024	7527	1272	6500	Head	6.102	34.582	PASS	PASS	OFDM	N/A	PASS

NOTE: The probes have been calibrated for both CW and modulated signals. Modulations in the table above represent test configurations for which the measurement system has been validated per FCC KDB Publication 865664 D01v01r04 for scenarios when CW probe calibrations are used with other signal types. SAR systems were validated for modulated signals with a periodic duty cycle, such as GMSK, or with a high peak to average ratio (>5 dB), such as OFDM according to FCC KDB Publication 865664 D01v01r04.

FCC ID: C3K-00002101	RF EXPOSURE PART 1 TEST REPORT	Approved by: Technical Manager
DUT Type: Wireless Module		APPENDIX G: Page 1 of 1