

SECTION 2.1033 (c) Label and label location - A photo showing the identification label clearly (you must be able to see the name and FCC ID number), and the location on the device. In lieu of a photo for this, you may submit an engineer's drawing.

Part 15.21 Statement - for all intentional and unintentional radiators is also printed on the label. All devices shall bear the following statement in a conspicuous location on the device:

“ This device complies with Part 15 of the FCC Rules Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. “

ENGINEERS DRAWING / LABEL ART:

Honeywell

MODEL NO. 5808W3AP
SMOKE
DETECTOR/TRANSMITTER

PHOTOELECTRONIC
DETECTION PRINCIPLE
AND 135°F (57°C)
THERMAL

MAXIMUM INSTALLATION
AMBIENT TEMPERATURE
100°F (37.8°C)

UL LISTED 5911

THIS DEVICE COMPLIES WITH PART 15 OF THE FCC RULES. OPERATION IS SUBJECT TO THE FOLLOWING TWO CONDITIONS: (1) THIS DEVICE MAY NOT CAUSE HARMFUL INTERFERENCE, AND (2) THIS DEVICE MUST ACCEPT ANY INTERFERENCE RECEIVED, INCLUDING INTERFERENCE THAT MAY CAUSE UNDESIRE OPERATION.

FCC ID: CFS8DL5808W3AP

SENSITIVITY RANGE 1.0-4.0%/FT

FOR REPAIR RETURN TO:
HONEYWELL
165 EILEEN WAY
SYOSSET, NY
11791 U.S.A.

TEST WEEKLY BY DEPRESSING THE TEST BUTTON

MADE IN MEXICO

N10742

APPROVED

N04-2460-00

WARNING: REPLACE BATTERY WITH A PANASONIC CR123A OR ADEMCO 466 ONLY. WAIT 10 SECONDS AFTER REMOVAL OF OLD BATTERY BEFORE INSERTING NEW BATTERY. USE OF ANOTHER BATTERY MAY PRESENT RISK OF FIRE OR EXPLOSION. SEE OWNER'S MANUAL FOR SAFETY PRECAUTIONS.

EXACT PHYSICAL LOCATION ON UNIT:

