
Appendix A. System Check Data

Test Laboratory: DEKRA

Date: 2024-07-22

System Performance Check_2450MHz-Head

Communication System: UID 0--, CW; Frequency: 2450.000 MHz

Medium parameters used: $f = 2450.000$ MHz; Conductivity = 1.78 S/m; Permittivity = 39.8

Phantom section: Flat

DASY Configuration:

- Probe: EX3DV4 - SN7784; ConvF(6.73, 6.93, 6.69); Calibrated: 2024-04-22
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1791; Calibrated: 2024-04-22
- Phantom: Twin-SAM V8.0 (30deg probe tilt)
- Measurement SW: V16.4.0.5005

Area Scan (40.0 mm x 80.0 mm): Measurement grid: 10.0 mm x 10.0 mm

SAR (1 g) = 13.5 W/kg; SAR (10 g) = 6.27 W/kg

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement grid: 5.0 mm x 5.0 mm x 1.5 mm

Power Drift = 0.01 dB

SAR(1 g) = 13.6 W/kg; SAR(10 g) = 6.44 W/kg

Smallest distance from peaks to all points 3 dB below = 9.0

Ratio of SAR at M2 to SAR at M1 = 82.2

