

EMC TEST REPORT

FCC 47 CFR Part 15B Industry Canada ICES-003

Electromagnetic compatibility - Unintentional radiators

Report Reference No. G0M-1704-6415-EF0115B-V01

Testing Laboratory: Eurofins Product Service GmbH

Address: Storkower Str. 38c

15526 Reichenwalde

Germany

Accreditation:





A2LA Accredited Testing Laboratory, Certificate No.: 1983.01

FCC Filed Test Laboratory, Reg.-No.: 96970 IC OATS Filing assigned code: 3470A

Applicant's name: Kieback & Peter GmbH & Co. KG

Address: Tempelhofer Weg 50

12347 Berlin GERMANY

Test specification:

Standard.....: 47 CFR Part 15 Subpart B

ICES-003, Issue 6:2016

ANSI C63.4:2014

Equipment under test (EUT):

Product description Actuator

Model No. MD15-CFL-HE

Additional Models None

Hardware version 11651000 MD15-FTL-CFL902

Firmware / Software version Test-SW: GWC1.2.0.3_TCM300HW_TCM320HW-868MHz

FCC-ID: NY3MD15CFL IC: N/A

Test result Passed



D!h	1- 4	44			-4
Possib	ie i	test	case	vera	Cts:

- not applicable to test object N/A

- test object does meet the requirement...... P (Pass)

- test object does not meet the requirement..... F (Fail)

Testing:

Compiled by: Andreas Pflug

Tested by (+ signature).....: Andreas Pflug

Approved by (+ signature):

Jens Marquardt

Deputy Head of Lab

Date of issue: 2017-07-17

Total number of pages: 29

General remarks:

The test results presented in this report relate only to the object tested.

The results contained in this report reflect the results for this particular model and serial number. It is the responsibility of the manufacturer to ensure that all production models meet the intent of the requirements detailed within this report.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

Additional comments:



Version History

Version	Issue Date	Remarks	Revised by
V01	2017-07-17	Initial Release	



REPORT INDEX

1	EQUIPMENT (TEST ITEM) DESCRIPTION	5
1.1	Photos – Equipment external	6
1.2	Photos – Equipment internal	8
1.3	Photos – Test setup	11
1.4	Supporting Equipment Used During Testing	13
1.5	Input / Output Ports	13
1.6	Operating Modes and Configurations	14
1.7	Test Equipment Used During Testing	15
1.8	Sample emission level calculation	16
2	RESULT SUMMARY	17
3	TEST CONDITIONS AND RESULTS	18
3.1	Test Conditions and Results – Radiated emissions	18





1 Equipment (Test item) Description

Description	Actuator
Model	MD15-CFL-HE
Additional Models	None
Serial number	SN: 097008.010 /1.00
Hardware version	11651000_MD15-FTL-CFL902
Software / Firmware version	Test-SW: GWC1.2.0.3_TCM300HW_TCM320HW-868MHz
FCC-ID	NY3MD15CFL
IC	N/A
Power supply	3.6 VDC (Lithium-battery)
Manufacturer	Kieback & Peter GmbH & Co. KG Tempelhofer Weg 50 12347 Berlin GERMANY
Highest emission frequency	Fmax [MHz] = 902.875
Sensitivity level	-90 dBm
Device classification	Class B
Equipment type	Tabletop
Number of tested samples	1




1.1 Photos – Equipment external









Product Service









1.2 Photos – Equipment internal









Product Service
















1.3 Photos - Test setup







Product Service





1.4 Supporting Equipment Used During Testing

Product Type*	Device	Manufacturer	Model No.	Comments (e.g. serial no.)
AE	Laptop	DELL	LATITUDE E6430	Property eurofins 4250257 +Software Kieback&Peter Astda V0.9.2
AE	USB-Gateway	enocean	USB 300U	Property K&P

*Note: Use the following abbreviations:

AE: Auxiliary/Associated Equipment, or SIM: Simulator (Not Subjected to Test)

CABL: Connecting cables

1.5 Input / Output Ports

Port #	Name	Type*	Max. Cable Length	Cable Shielded	Comments (e.g. Cat. of Cable)
N/A					

*Note: Use the following abbreviations:

AC : AC power port
DC : DC power port
N/E : Non electrical

I/O : Signal input or output port
TP : Telecommunication port



1.6 Operating Modes and Configurations

Mode #	Description
1	continuous transmit (TX)
2	RX mode with continuous manual variation of the actuator Soll-Position between 0% and 100% (RX)

Configuration #	EUT Configuration
1	EUT fully assabled



1.7 Test Equipment Used During Testing

Measurement Software						
Description	Manufacturer	Name	Version			
EMC Test Software	Dare Instruments	Radimation	2016.1.10			

Radiated emissions AC6								
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due			
TRILOG Broadband Antenna	Schwarzbeck	VULB 9162	EF00978	2016-11	2017-11			
Double-Ridged Guide Antenna	ETS-Lindgren	3117	EF00976	2016-03	2019-03			
EMI Test Receiver	R&S	ESU26	EF00887	2017-01	2018-01			
RF Cable	Huber & Suhner	Sucoflex 106	-	System Cal.	System Cal			
RF Cable	Huber & Suhner	Multiflex 141	-	System Cal.	System Cal			



1.8 Sample emission level calculation

The following is a description of terms and a sample calculation, as appears in the radiated emissions data table. The numbers used in the calculation are for example only. There is no direct correlation to the specific data taken for the product described in this document:

Reading:

This is the reading obtained on the spectrum analyzer in dBµV. Any external preamplifiers used are taken into account through internal analyzer settings.

A.F.:

This is the antenna factor for the receiving antenna. It is a conversion factor, which converts electric fields strengths to voltages, which can be measured directly on the spectrum analyzer. It is treated as a loss in dB. Cable losses have been included with the A.F. to simplify the calculations. The antenna factor is used in calculations as follows:

Reading on Analyzer ($dB\mu V$) + A.F. (dB) = Net field strength ($dB\mu V/m$)

Net:

This is the net field strength measurement (as shown above).

Limit:

This is the FCC Class B radiated emission limit (in units of $dB\mu V/m$). The FCC limits are given in units of $\mu V/m$. The following formula is used to convert the units of $\mu V/m$ to $dB\mu V/m$:

Limit $(dB\mu V/m) = 20*log (\mu V/m)$

Margin:

This is the margin of compliance below the FCC limit. The units are given in dB. A negative margin indicates the emission was below the limit. A positive margin indicates that the emission exceeds the limit.

Example only:

Reading + AF = Net Reading : Net reading - FCC limit = Margin 21.5 dB μ V + 26 dB = 47.5 dB μ V/m : 47.5 dB μ V/m - 57.0 dB μ V/m = -9.5 dB



2 Result Summary

FCC 47 CFR Part 15B, Industry Canada ICES-003							
Product Specific Standard	Requirement – Test	Reference Method	Result	Remarks			
47 CFR 15.109 ICES-003 Item 6.2	Radiated emissions	ANSI C 63.4	PASS				
47 CFR 15.107 ICES-003 Item 6.1	AC power line conducted emissions	ANSI C63.4	N/A	only battery powered			
Remarks:		·					



3 Test Conditions and Results

3.1 Test Conditions and Results - Radiated emissions

Radiated emission	ons acc. FCC 47 C	FR 15.109	9 / ICES-003	Verdict: PASS				
Laboratory	Parameters:	Required prior to the test						
Ambient T	emperature		15 to 35 °C		22 °C			
Relative	Humidity		30 to 60 %		35 %			
Test accordi	ng referenced		Reference	e Metho	d			
stan	dards		ANSI	C63.4				
Sample is tested	with respect to the		Equipmo	ent class				
requirements of the	ne equipment class		Cla	ss B				
Test frequency ran	ge determined from		Highest emiss	sion freq	uency			
highest emiss	highest emission frequency		Fmax [MHz] = 902.875					
Fully configured sa	ample scanned over	Frequency range						
the following fr	requency range	30 MHz to 6 GHz						
Operati	ng mode	1 + 2						
Config	juration	1						
	L	imits and results Class B						
Frequency [MHz]	Quasi-Peak [dBµV/r	n] Result	Average [dBµV/m]	Result	Peak [dBµV/m]	Result		
30 – 88	40	PASS	-		-	-		
88 – 216	43.5	PASS	-		-	-		
216 – 960	46	PASS	-		-	-		
960 – 1000	54	PASS	-		-	-		
1000 - 6000	-	-	54	PASS	74	PASS		
Comment: also in 3	m distance no disturb	ance from	the actuator					



Test Procedure:

The test site is in accordance with ANSI C63-4:2014 requirements and is listed by FCC. The measurement procedure is as follows:

Exploratory measurement:

- The EUT was placed on a non-conductive table at a height of 0.8m.
- The EUT and support equipment, if needed, were set up to simulate typical usage.
- Cables, of type and length specified by the manufacturer, were connected to at least one port of each type and were terminated by a device or simulating load of actual usage.
- The antenna was placed at a distance of 3 or 10 m.
- The received signal was monitored at the measurement receiver.
 - Cables not bundled were manipulated within the range of likely arrangements to produce the highest emission amplitude
 - To maximize the suspected emissions the EUT is rotated 360 degrees. If the signal exceeds the previous amplitude, go back to the corresponding azimuth and manipulate the cables again for maximizing the emissions if possible.
 - Move the antenna from 1 to 4m to maximize the suspected highest amplitude signal.
- This procedure has to be performed in both antenna polarizations, horizontal and vertical.
- The arrangement of the equipment with the maximum emission level is shown on the setup picture at item 1.3.

Final measurement:

- The EUT was placed on a 0.8 m non-conductive table at a 3 m distance from the receive antenna. The antenna output was connected to the measurement receiver
- A biconical antenna was used for the frequency range 30 200 MHz, a logarithmic periodical antenna was used for the frequency range from 200 – 1000 MHz. Above one 1 GHz a Double Ridged Broadband Horn antenna was used. The antenna was placed on an adjustable height antenna mast
- The EUT and cable arrangement were based on the exploratory measurement results
- Emissions were maximized at each frequency by rotating the EUT and adjusting the receive antenna height and polarization. The maximum values were recorded.
- The test data of the worst-case conditions were recorded and shown on the next pages.



Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug


Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: Schwarzbeck VULB 9162, Horizontal

Measurement distance: 10m Mode: TX

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug


Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: Schwarzbeck VULB 9162, Vertical

Measurement distance: 10m Mode: TX

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug


Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: ETS-Lindgren 3117, Vertical

Measurement distance: 3 m Mode: TX

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug


Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: ETS-Lindgren 3117, Horizontal

Measurement distance: 3 m Mode: TX

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)


Antenna: Schwarzbeck VULB 9162, Vertical

Measurement distance: 10m

Mode: 2 without actuator-motor

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)


Antenna: Schwarzbeck VULB 9162, Horizontal

Measurement distance: 10m

Mode: 2 without actuator-motor

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)


Antenna: ETS-Lindgren 3117, Vertical

Measurement distance: 3 m

Mode: 2 without actuator-motor

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator
Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)


Antenna: ETS-Lindgren 3117, Horizontal

Measurement distance: 3 m

Mode: 2 without actuator-motor

Test Date: 2017-05-09

Note:





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH


Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: Schwarzbeck VULB 9162, Horizontal

Measurement distance: 10 m Mode: 2

Test Date: 2017-05-09 Note: worst case!





Project number: G0M-1704-6415

Applicant: Kieback & Peter GmbH & Co. KG

EUT Name: Actuator Model: MD15-CFL-HE

Test Site: Eurofins Product Service GmbH

Operator: Mr. Pflug

Test Conditions: Tnom: 22°C, Unom: 3.6VDC (battery, Li-SOCL2)

Antenna: Schwarzbeck VULB 9162, Vertical

Measurement distance: 10 m Mode: 2

Test Date: 2017-05-09

Note:

