

# Appendix A

## Detailed System Check Results

1. System Performance Check
System Performance Check 750 MHz Head
System Performance Check 835 MHz Head
System Performance Check 1750 MHz Head
System Performance Check 1900 MHz Head
System Performance Check 2450 MHz Head
System Performance Check 2600 MHz Head
System Performance Check 5250 MHz Head
System Performance Check 5600 MHz Head
System Performance Check 5750 MHz Head



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

**Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com**

SGS-CSTC Standards Technical Services Co., Ltd.  
Shenzhen Branch / 深圳分公司  
No.1 Workshop, M-10, Middle Section, Science & Technology Park, Nanshan District, Shenzhen, Guangdong, China 518057  
中国·广东·深圳市南山区科技园中区M-10栋1号厂房 邮编: 518057

t (86-755) 26012053 f (86-755) 26710594 www.sgs.com.cn  
t (86-755) 26012053 f (86-755) 26710594 sgs.china@sgs.com

System Performance Check 750MHz Head


D750V3-SN 1160

Communication System: ; Frequency: 750.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f=750.000\text{ MHz}$ ;  $\sigma=0.867\text{ S/m}$ ;  $\epsilon_r=43.0$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(10.0, 10.0, 10.0); Calibrated: 2024-08-29
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 15.0 mm  
SAR (1g) = 1.96 W/kg; SAR (10g) = 1.31 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm  
Power Drift = 0.03 dB  
**SAR (1g) = 1.98 W/kg; SAR (10g) = 1.29 W/kg;**  
M2/M1 [%]=82.9  
Dist 3dB Peak [mm]=16.9



Test Laboratory: SGS-SAR Lab

## System Performance Check 835 MHz Head

**DUT: D835V2; Type: Dipole; Serial: 4d105**

Communication System: UID 0, CW (0); Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL835; Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.936 \text{ S/m}$ ;  $\epsilon_r = 40.185$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

DASY 5 Configuration:

- Probe: EX3DV4 - SN7620; ConvF(9.87, 10.58, 10.42); Calibrated: 2024/7/29
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn867; Calibrated: 2024/12/31
- Phantom: SAM 1; Type: SAM; Serial: 1912
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

**Configuration/d=15mm, Pin=250mW/Area Scan (6x13x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (measured) =  $3.27 \text{ W/kg}$

**Configuration/d=15mm, Pin=250mW/Zoom Scan (5x5x7)/Cube 0:** Measurement grid:  $dx=8\text{mm}$ ,  $dy=8\text{mm}$ ,  $dz=5\text{mm}$

Reference Value =  $52.68 \text{ V/m}$ ; Power Drift =  $0.04 \text{ dB}$


Peak SAR (extrapolated) =  $3.70 \text{ W/kg}$

**SAR(1 g) =  $2.55 \text{ W/kg}$ ; SAR(10 g) =  $1.67 \text{ W/kg}$**

Smallest distance from peaks to all points 3 dB below =  $16 \text{ mm}$

Ratio of SAR at M2 to SAR at M1 =  $66.9\%$

Maximum value of SAR (measured) =  $3.35 \text{ W/kg}$



0 dB =  $3.27 \text{ W/kg}$  =  $5.14 \text{ dBW/kg}$

System Performance Check 835 MHz Head


D835V2-SN 4d105

Communication System: D835; Frequency: 835.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f=835.000\text{ MHz}$ ;  $\sigma=0.934\text{ S/m}$ ;  $\epsilon_r=42.1$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(10.36, 10.36, 10.36); Calibrated: 2024-07-17
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (100.0 mm x 180.0 mm):** Measurement Grid: 10.0 mm x 10.0 mm  
SAR (1g) = 2.40 W/kg; SAR (10g) = 1.58 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm  
Power Drift = -0.15 dB  
**SAR (1g) = 2.48 W/kg; SAR (10g) = 1.61 W/kg;**  
M2/M1 [%]=62.7  
Dist 3dB Peak [mm]=17.3



System Performance Check 1750MHz Head


D1750V2-SN 1149

Communication System: ; Frequency: 1750.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 1750.000$  MHz;  $\sigma= 1.32$  S/m;  $\epsilon_r = 39.0$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(8.19, 8.19, 8.19); Calibrated: 2024-08-29
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 15.0 mm  
SAR (1g) = 8.98 W/kg; SAR (10g) = 4.88 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm  
Power Drift = 0.00 dB  
**SAR (1g) = 9.16 W/kg; SAR (10g) = 4.87 W/kg;**  
M2/M1 [%]=80.2  
Dist 3dB Peak [mm]=10.8



System Performance Check 1900MHz Head


D1900V2- SN 5d028

Communication System: ; Frequency: 1900.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 1900.000$  MHz;  $\sigma= 1.42$  S/m;  $\epsilon_r = 40.1$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(7.86, 7.86, 7.86); Calibrated: 2024-08-29
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 15.0 mm  
SAR (1g) = 10.5 W/kg; SAR (10g) = 5.51 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm  
Power Drift = 0.01 dB  
**SAR (1g) = 10.8 W/kg; SAR (10g) = 5.53 W/kg;**  
M2/M1 [%]=79.7  
Dist 3dB Peak [mm]=9.6



System Performance Check 2450 MHz Head


D2450V2-SN 733

Communication System: D2450; Frequency: 2450.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 2450.000$  MHz;  $\sigma= 1.80$  S/m;  $\epsilon_r = 40.2$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7838; ConvF(7.13, 6.8, 7.01); Calibrated: 2024-11-20
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (72.0 mm x 96.0 mm):** Measurement Grid: 12.0 mm x 12.0 mm  
SAR (1g) = 12.6 W/kg; SAR (10g) = 5.84 W/kg;

**Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm):** Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm  
Power Drift = -0.01 dB  
**SAR (1g) = 11.8 W/kg; SAR (10g) = 5.65 W/kg;**  
M2/M1 [%]=51.2  
Dist 3dB Peak [mm]=9.0



System Performance Check 2600MHz Head


D2600V2-SN 1125

Communication System: ; Frequency: 2600.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 2600.000$  MHz;  $\sigma= 1.96$  S/m;  $\epsilon_r = 38.7$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(7.33, 7.33, 7.33); Calibrated: 2024-08-29
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 15.0 mm  
SAR (1g) = 14.7 W/kg; SAR (10g) = 6.61 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm  
Power Drift = -0.01 dB  
**SAR (1g) = 14.9 W/kg; SAR (10g) = 6.69 W/kg;**  
M2/M1 [%]=77.9  
Dist 3dB Peak [mm]=9.0





System Performance Check 5250 MHz Head


D5GHzV2-SN 1165

Communication System: D5GHz; Frequency: 5250.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 5250.000$  MHz;  $\sigma= 4.50$  S/m;  $\epsilon_r = 36.1$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7838; ConvF(5.52, 5.26, 5.42); Calibrated: 2024-11-20
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (60.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 10.0 mm  
SAR (1g) = 7.54 W/kg; SAR (10g) = 2.24 W/kg;

**Zoom Scan (24.0 mm x 24.0 mm x 22.0 mm):** Measurement Grid: 4.0 mm x 4.0 mm x 2.0 mm  
Power Drift = -0.01 dB  
**SAR (1g) = 8.07 W/kg; SAR (10g) = 2.36 W/kg;**  
M2/M1 [%]=55.5  
Dist 3dB Peak [mm]=7.2



System Performance Check 5600 MHz Head


D5GHzV2-SN 1165

Communication System: D5GHz; Frequency: 5600.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 5600.000$  MHz;  $\sigma= 5.06$  S/m;  $\epsilon_r = 35.8$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7838; ConvF(5.07, 4.84, 4.98); Calibrated: 2024-11-20
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4 Sn1267; Calibrated: 2024-01-03
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (60.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 10.0 mm  
SAR (1g) = 7.04 W/kg; SAR (10g) = 2.02 W/kg;

**Zoom Scan (24.0 mm x 24.0 mm x 22.0 mm):** Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm  
Power Drift = -0.08 dB  
**SAR (1g) = 8.02 W/kg; SAR (10g) = 2.31 W/kg;**  
M2/M1 [%]=63.6  
Dist 3dB Peak [mm]=6.9



System Performance Check 5750 MHz Head


D5GHzV2-SN 1165

Communication System: D5GHz; Frequency: 5750.000  
Medium: Head Simulating Liquid. Medium parameters used:  $f= 5750.000$  MHz;  $\sigma= 5.23$  S/m;  $\epsilon_r = 35.4$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7838; ConvF(5.18, 4.94, 5.09); Calibrated: 2024-11-20
  - Sensor-Surface: 1.4 mm
  - Electronics: DAE4 Sn1267; Calibrated: 2024-01-03
  - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
  - Measurement Software: cDASY8 V16.4.0.5005

**Area Scan (60.0 mm x 90.0 mm):** Measurement Grid: 10.0 mm x 10.0 mm  
SAR (1g) = 6.68 W/kg; SAR (10g) = 1.97 W/kg;

**Zoom Scan (22.0 mm x 22.0 mm x 22.0 mm):** Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm  
Power Drift = -0.00 dB  
**SAR (1g) = 6.97 W/kg; SAR (10g) = 2.04 W/kg;**  
M2/M1 [%]=62.3  
Dist 3dB Peak [mm]=7.6



# SGS-CSTC Standards Technical Services Co., Ltd. Shenzhen Branch

SZSAR-TRF-01-A03 Rev. A/0 Aug 16,2024

Report No.: SZCR250100004909

Page: 12 of 12

- End of the Appendix -



SGS-CSTC Standards Technical Services Co., Ltd.  
Shenzhen Branch

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

**Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com**

No.1 Workshop, M-10, Middle Section, Science & Technology Park, Nanshan District, Shenzhen, Guangdong, China 518057 t (86-755) 26012053 f (86-755) 26710594 www.ssgroup.com.cn  
中国·广东·深圳市南山区科技园中区M-10栋1号厂房 邮编: 518057 t (86-755) 26012053 f (86-755) 26710594 sgs.china@sgs.com