



Label Requirement Document

July 23, 2018

MET Laboratories, Inc.
914 West Patapsco Avenue
Baltimore, MD 21230

RE: Label Requirement

To Whom It May Concern:

The High Bay Sensor Dimming Controller (HBS-DC), is physically too small to support a label indicating the appropriate language as indicated by the FCC. In order to meet this label requirement, the language is included in the User's Manual. This note is included herein for reference.

NOTE: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

Please contact me if there is any information you may need.

Sincerely,

A handwritten signature in blue ink. The signature appears to read "Mark Plasterer" and is written in a cursive, flowing style.

Mark Plasterer
Hardware Engineering Manager
Autani, LLC